



# SML WALL T5

 Die durchgestrichene Mülltonne weist darauf hin, dass dieses Elektrogerät nicht im Hausmüll entsorgt werden darf.

Um die menschliche Gesundheit und die Umwelt vor möglichen Gefahrstoffen zu schützen, kann dieses Produkt am Ende seiner Lebensdauer kostenfrei bei einer Sammelstelle in Ihrer Nähe abgegeben werden.

Die gesonderte Entsorgung ermöglicht die Wiederverwendung bzw. Verwertung von Elektrogeräten.

 The crossed-out wheelie bin indicates that this electrical appliance must not be disposed of via household waste.

In order to protect human health and the environment against potentially hazardous substances, at the end of its lifecycle this product can be taken to a collection point close to you and disposed of free of charge there.

This separate disposal enables electrical appliances to be reused or recycled.

## Please note the following technical recommendations:

Assuming a switching rhythm in accordance with IEC (165 minutes on, 15 minutes off) the illuminants should be replaced by a new one after 18,000 hours (corresponds to approx. 4 years given a daily operating time of 12 hours). When replacing the illuminant we recommend the use of original manufacturer's items. Furthermore, when replacing the illuminant the luminaire must be disconnected from the mains!

In principle it can be assumed that insufficient or excessive power to the illuminants will reduce their lifespan. The following measures contribute to a stable lifespan:

1. Switching the lamp on and off as little as possible.
2. Keeping switching cycle times always longer than a minimum of 10 minutes.
3. Monitoring light output. Should the output dwindle early, replace the illuminant prematurely.

Furthermore, should the luminaire be in a vertical position, make sure the manufacturer's specification stamp on the new illuminant is at the bottom! If our luminaires are in a vertical position or several are aligned directly next to each other, make sure that when changing an illuminant the specification stamp on the new is on the same side in each case.

Disposal of illuminants:  
Fluorescent lamps contain small quantities of mercury and as such must not be disposed of in domestic refuse. As of March 24, 2006 manufacturers are legally obliged to take back all fluorescent lamps and dispose of these in accordance with regulations. For detailed information please contact your local waste disposal authority or the manufacturers' own joint company LIGHTCYCLE.

## Bitte beachten Sie die folgenden technischen Hinweise:












Bei einem zugrunde gelegten Schaltrhythmus nach IEC (165 Min. ein, 15 Min. aus) sollten die Leuchtmittel nach 18.000 Stunden gegen neue Leuchtmittel ausgetauscht werden. Dies entspricht etwa 4 Jahren bei einer täglichen Beleuchtungsdauer von 12 Stunden. Beim Wechsel der Leuchtmittel empfehlen wir den Einsatz der originalen Herstellerbestückung. Während des Leuchtmittelwechsels darf keine Netzspannung an der Leuchte anliegen!

Grundsätzlich ist davon auszugehen, dass Unter- oder Überlastungen der Leuchtmittel zu einer Verkürzung der Lebensdauer führen. Folgende Maßnahmen tragen maßgeblich zu einer stabilen Service-Lebensdauer bei:

1. Möglichst wenig Schaltvorgänge (Ein/Aus) initiieren.
2. Schaltzyklenzeiten immer länger als 10 Min. halten.
3. Lichtleistung beobachten. Bei frühzeitiger Abnahme der Lichtleistung vorzeitig das Leuchtmittel austauschen.

Bei vertikaler Anordnung der Leuchte ist außerdem zu beachten, dass sich der Stempel des neuen Leuchtmittels unten befindet! Bei horizontaler, mehrfacher (direkt nebeneinander) Anordnung unserer Leuchten sollte bei einem Leuchtmittelwechsel darauf geachtet werden, dass sich die Stempel der neuen Leuchtmittel jeweils auf der gleichen Seite befinden.

Entsorgung der Leuchtmittel:  
Leuchtstofflampen enthalten geringe Mengen Quecksilber und dürfen nicht durch den Hausmüll entsorgt werden. Die Hersteller nehmen im Rahmen ihrer gesetzlichen Verpflichtung alle Leuchtstofflampen zurück und entsorgen diese ordnungsgemäß. Für detaillierte Informationen wenden Sie sich bitte an Ihren örtlichen Entsorger oder das herstellereigene Gemeinschaftsunternehmen LIGHTCYCLE.

	S	M	L
mm	600x85x25	900x85x25	1200x85x25
kg (lbs)	1,0 (2.2)	1,3 (2.9)	1,8 (4.0)
	24 W/G5 OSRAM LUMILUX FQ 24W / 840 (Coolwhite) / HO CONSTANT 1750 lm <sup>1</sup>	39 W/G5 OSRAM LUMILUX FQ 39W / 840 (Coolwhite) / HO CONSTANT 3100 lm <sup>1</sup>	54 W/G5 OSRAM LUMILUX FQ 54W / 840 (Coolwhite) / HO CONSTANT 4450 lm <sup>1</sup>
     			
   			

<sup>1</sup> max. Lichtstrom bei 25°C Umgebungstemperatur. Den maximalen Lichtstrom erreichen die Leuchtstofflampen erst ab einer Mindest(ein)brenndauer von 100 Std. max. luminous flux at 25°C ambient temperature. Fluorescent lamps achieve their maximum luminous flux only after the first 100 hours of operating time.

**D** Vor Montage der Leuchte Sicherung ausschalten!  
 Lage des EVG. Keine Bohrung ins Leuchten-  
 gehäuse! Vorsicht, Hochspannung!

**GB** Disconnect fuse prior to installation!  
 Location of electronic ballast. Do not bore the  
 lamp housing! Caution, high voltage!

**F** Pour la pose de luminaire, couper le courant!  
 Position de l'équipement électronique. Ne  
 transpercez pas le boîtier de la lampe.  
 Danger, haute tension!

**I** Assicurarsi che la lampada si spenta prima del  
 montaggio! Ubicazione del reattore elettronico.  
 Nessun buco nella lampada.  
 Attenzione, high voltage

